

BILANS MOCY I DOBÓR ZABEZPIECZEŃ

LP	ODBIÓRNIK	Pi [kW]	kz	cos fi	Pszcz [Kw]	Qszcz [kVAr]	Sszcz [kVA]	I _{obc} Id[A]	I _{ab} [A]
1	Kompensator 10kVar	10,0	1,00	1,00	10,0	0,0	10,0	14,5	16